

Samples Collected and Analyzed by Louisville Water Company									
Site Description	City	State	River	River Mile	Sample Depth	Date	Time	n-Butyl Acrylate (ppb)	other VOCs (ppb)*
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/3/2023	0700		Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/4/2023	0715		Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/5/2023	0715		Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/6/2023	0724		Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/7/2023	0700		Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/8/2023	0715		Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/9/2023	0700		Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/10/2023	0700		Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/11/2023	0700	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/12/2023	0715	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/13/2023	0700	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/14/2023	0700	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/15/2023	0715	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/16/2023	0715	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/17/2023	0700	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/17/2023	1338	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/18/2023	0730	Not Detected	Not Detected
Westport	Westport	KY	Ohio River	580	Surface Grab	2/18/2023	1335	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/18/2023	1435	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/19/2023	0730	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/19/2023	1040	Not Detected	Not Detected
Carrollton	Carrollton	KY	Ohio River	545	Surface Grab	2/19/2023	1150	Not Detected	Not Detected
Westport	Westport	KY	Ohio River	580	Surface Grab	2/19/2023	1306	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/19/2023	1517	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Surface Grab	2/19/2023	1900	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Mid Grab	2/19/2023	1902	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Bottom Grab	2/19/2023	1904	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Surface Grab	2/19/2023	2100	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Mid Grab	2/19/2023	2105	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Bottom Grab	2/19/2023	2110	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Surface Grab	2/19/2023	2300	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Mid Grab	2/19/2023	2305	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Bottom Grab	2/19/2023	2310	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Surface Grab	2/20/2023	0100	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Mid Grab	2/20/2023	0105	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Bottom Grab	2/20/2023	0110	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/20/2023	0105	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Surface Grab	2/20/2023	0300	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Mid Grab	2/20/2023	0305	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Bottom Grab	2/20/2023	0310	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Surface Grab	2/20/2023	0500	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Mid Grab	2/20/2023	0505	Not Detected	Not Detected
Markland	Warsaw	KY	Ohio River	531	Bottom Grab	2/20/2023	0510	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/20/2023	0731	Not Detected	Not Detected
Carrollton	Carrollton	KY	Ohio River	546	Surface Grab	2/20/2023	0735	Not Detected	Not Detected
Madison	Madison	IN	Ohio River	557	Surface Grab	2/20/2023	0756	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/20/2023	0843	Not Detected	Not Detected
Westport	Westport	KY	Ohio River	580	Surface Grab	2/20/2023	0900	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/20/2023	0943	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/20/2023	1145	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/20/2023	1500	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/20/2023	1600	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/20/2023	1800	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/21/2023	2157	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/21/2023	0158	Not Detected	Not Detected
Zorn Pump Station	Louisville	KY	Ohio River	600	Intake	2/21/2023	0600	Not Detected	Not Detected
*Louisville Water analyzes daily for volatile organic compounds (VOCs) in water using EPA method 524									
Not detected means the analytical results were less than the minimum reporting limit of 0.50 ppb									